



DEPARTMENT OF EDUCATION OFFICE OF THE SUPERINTENDENT

www.gdoe.net
500 Mariner Avenue
Barrigada, Guam 96913

Telephone: (671) 300-1547/1536 • Fax: (671) 472-5001

JON J. P. FERNANDEZ
Superintendent of Education



GDOE SCHOOL BUILDING INSPECTION REPORT

REASON	INSPECTION STARTED	SCHOOL NAME:
REGULAR	DATE 12/24/15	Simon Sanchez High School
FOLLOW-UP	INSPECTION TIME	DEPARTMENT/DIVISION:
COMPLAINT	3 HR. MIN.	Guam Department of Education
INVESTIGATION	INSPECTION ENDED	ADDRESS:
OTHER (Specify) <input checked="" type="checkbox"/>	DATE 12/24/15	395 Juan Jacinto Road, Yigo Guam 96929
SANITARY PERMIT # 150000420		PERMIT CATEGORY STATUS (Circle One) Permanent Temporary Current Expired

Based on an inspection this day, the items listed below identify violations in operation or facilities which must be corrected by the next routine inspection or such shorter period of time as many be specified by the Department. Failure to comply may result in cessation of your operations.

ITEM NO.	REMARKS	Total Demerits
3	<ul style="list-style-type: none"> No evacuation map for pull station. Evacuation maps not posted in the classrooms. 	2
13	<ul style="list-style-type: none"> Walls and ceilings needs to be cleaned in all the classrooms we inspected. Ceiling tiles cracked in Room 104. Water spots on the ceilings in Room 101, 229, girl's restroom near Room 230 above 3rd stall. Wall cracked leading up to the roof top in the library. Exposed ceiling tiles above staircase near Room 213. Paint peeling behind the gym (outside). 	2
14	<ul style="list-style-type: none"> Double door handle needs to be repaired in Room 215. 	4
18	<ul style="list-style-type: none"> Improper storage in Room 103 (electrical light bulb behind computer box). Instructional material on the floor in Room 103. Improper storage behind the gym. Choir props needs to be stored properly in the Choir room. 	2
19	<ul style="list-style-type: none"> Exit door is not properly used due to blockage. Exposed cords in Room 103. 	2

I have read and understand the above violation(s) and I am aware of the corrective measures to be taken.

*When any of the following items are cited above, see grade and timeline as to when violations need to be address:

- A - (0-10) Correct violations within 30 working days
- B - (11-20) Correct violations within 15 working days
- C - (21-40) Correct violations within 10 working days
- D - (41 or greater) Immediately

RECEIVED BY (Name and Title)

Philip Tenorio PRINCIPAL
GDOE INSPECTOR (Name and Title)

Philip Tenorio

Custodian

GDOE INSPECTOR (Name and Title)

Alvina Lynn S. Toves

Clerk Typist I



DEPARTMENT OF EDUCATION OFFICE OF THE SUPERINTENDENT

www.gdoe.net
500 Mariner Avenue
Barrigada, Guam 96913

Telephone: (671) 300-1547/1536 • Fax: (671) 472-5001

JON J. P. FERNANDEZ
Superintendent of Education



GDOE SCHOOL BUILDING INSPECTION REPORT

REASON		INSPECTION STARTED	SCHOOL NAME:
REGULAR		DATE 12/24/15	Simon Sanchez High School
FOLLOW-UP		INSPECTION TIME 3 HR. MIN.	DEPARTMENT/DIVISION:
COMPLAINT			Guam Department of Education
INVESTIGATION		INSPECTION ENDED	ADDRESS:
OTHER (Specify)	X	DATE 12/24/15	395 Juan Jacinto Road, Yigo Guam 96929
		SANITARY PERMIT # 150000420	PERMIT CATEGORY STATUS (Circle One) Permanent Temporary Current Expired

Based on an inspection this day, the items listed below identify violations in operation or facilities which must be corrected by the next routine inspection or such shorter period of time as many be specified by the Department. Failure to comply may result in cessation of your operations.

ITEM NO.	REMARKS	Total Demerits
21	<ul style="list-style-type: none"> Adequate odor in the girl's and boy's restroom (100's and 200's building). Dusty and covered diffusers in all the room, restroom and hallways we inspected. 	2
23	<ul style="list-style-type: none"> Needs light shield protector in Room 230 and 226. Lights not working in Room 213 (10 light bulbs out). Girl's restroom completely burnt out near Room 212. 	2
31	<ul style="list-style-type: none"> The following toilet facilities were observed to either unsanitary, and/or not properly supplied with toilet tissue, paper towels, soap, and liners for the trash bins. *Trash bins that are 33 gallons or more, needs to have the lids on. *Girl's restroom near Rooms 101, 230 and 212. *Boy's restroom near Room 106, 218 and the boy's restroom in the gym. *NO soap dispenser in the girl's restroom near Room 104. 	6
36	<ul style="list-style-type: none"> Fire extinguish were on the floors in Room 103, 230, 202, 207, 206 	4

I have read and understand the above violation(s) and I am aware of the corrective measures to be taken.

*When any of the following items are cited above, see grade and timeline as to when violations need to be address:

- A - (0-10) Correct violations within 30 working days
- B - (11-20) Correct violations within 15 working days
- C - (21-40) Correct violations within 10 working days
- D - (41 or greater) Immediately

RECEIVED BY (Name and Title)

Philip Tenorio
GDOE INSPECTOR (Name and Title)


Philip Tenorio





Custodian






GDOE INSPECTOR (Name and Title)


Alvina Lynn S. Toves


Clerk Typist I









REASON		INSPECTION STARTED	SCHOOL NAME:
REGULAR		DATE 02/29/16	Simon Sanchez High School
FOLLOW- UP	X	INSPECTION TIME	DEPARTMENT/DIVISION:
COMPLAINT		2 HR. MIN.	Guam Department of Education
INVESTIGATION		INSPECTION ENDED	ADDRESS:
OTHER (Specify)		DATE 02/29/16	395 Juan Jacinto Road, Yigo Guam 96929
		SANITARY PERMIT #	PERMIT CATEGORY STATUS (Circle One)
		150000420	Permanent Temporary Current Expired
Based on an inspection this day, the items listed below identify violations in operation or facilities which must be corrected by the next routine inspection or such shorter period of time as many be specified by the Department. Failure to comply may result in cessation of your operations.			
ITEM NO.	REMARKS		Total Demerits
13	• Water spots on the ceilings in Room 101, 229, girl's restroom near Room 230 above 3 rd stall.		2
	• Wall cracked leading up to the roof top in the library.		
	• Paint peeling behind the gym (outside).		
31	• NO soap dispenser in the girl's restroom near Room 104.		6
36	• Fire extinguisher are still on the floors in the following rooms 202, 206 and 230.		4
I have read and understand the above violation(s) and I am aware of the corrective measures to be taken.			
*When any of the following items are cited above, see grade and timeline as to when violations need to be address: A – (0-10) Correct violations within 30 working days B – (11-20) Correct violations within 15 working days C – (21-40) Correct violations within 10 working days D – (41 or greater) Immediately		RECEIVED BY (Name and Title) 	
		Principal	
		GDOE INSPECTOR (Name and Title) Philip Tenorio	
		Custodian	
		GDOE INSPECTOR (Name and Title) Alvina Lynn S. Toves	
		Clerk Typist I	